

# Annual Drinking Water Quality Report for 2022



## Powdersville Water MEETS ALL STANDARDS

Powdersville Water (PW) is very pleased to provide you with the 2022 Annual Drinking Water Quality Report. Keeping you, our customer, informed about water quality and the services that we deliver to you every day is of great importance to us. PW's primary goal is, and always will be, to provide you with a safe and dependable supply of drinking water. The Environmental Protection Agency (EPA) and the South Carolina Department of Health & Environmental Control (SCDHEC) have established strict standards for drinking water. These standards are in place to ensure consumers receive safe drinking water. PW is pleased to

report that our drinking water is safe and meets all of the federal and state standards. Each year, we collect hundreds of bacteriological samples, system-wide, to ensure your drinking water is safe. The samples are analyzed by a private lab that is certified by SCDHEC.

In addition, PW continually conducts a System Flushing Program to ensure adequate chlorine residual is maintained throughout the system for proper disinfection of your drinking water. The enclosed reports are further indication that PW is meeting the requirements of the law, and the bottom line is that you have safe, high-quality drinking water.

### HOW IS YOUR WATER TREATED?

Each of the filtration facilities that provide water to PW uses similar processes that involve coagulation, sedimentation, filtration and disinfection. Coagulation is a process by which a chemical, such as alum, is added to help small particles settle out from the source water. The pH is adjusted with very small amounts of sodium hydroxide, or caustic soda, filtration occurs, polyphosphates are added for corrosion control, chlorine and ammonia are added for disinfection, and fluoride is provided to prevent tooth decay. We are fortunate that each of our suppliers has modern facilities that continually provide our community with quality drinking water. In addition, each of our suppliers has a Source Water Assessment filed at SCDHEC. This document summarizes an in-depth survey of the watershed for each of our suppliers. Part of the report outlines an inventory of the potential contaminant sources (PCS) that are located in each watershed. Each PCS is then assigned a level of severity based upon its potential to contaminate the source water. The assessment provides a good planning tool for future growth and is designed to inform public officials and the general public of how our daily living practices may impact our sources of drinking water. In addition, the report outlines measures of protection for each watershed. If you would like to review these documents, please contact SCDHEC at (803) 898-4300.



### Where Does YOUR WATER COME FROM?

Your drinking water originates from three separate suppliers. Greenville Water and Anderson Regional Joint Water System (ARJWS) are primary, while Easley Combined Utilities is utilized as an auxiliary source. PW purchases water from these suppliers by means of several connections throughout the system. Each supplier provides filtered surface water to PW that is treated to SCDHEC Drinking Water Standards. Greenville Water supplies PW its treated water from Lake Keowee and ARJWS supplies water from Lake Hartwell, both using state-of-the-art filtration plants. Treated water from Saluda Lake is the third source (auxiliary) that is provided by Easley Combined Utilities. We are very fortunate in the Powdersville Community to have several pristine sources of surface water to draw from to provide an adequate water supply for our growing population during normal weather conditions, as well as during drought conditions.

### WANT TO KNOW MORE?

For more information about your quality drinking water source, simply call our Operator of Record, Chris Rasco, at Powdersville Water office at **864-269-5440**.

#### FOR MORE INFORMATION

Powdersville Water  
visit our website at

[www.PowdersvilleWater.org](http://www.PowdersvilleWater.org)



# HOW TO READ THE DATA

## Explanation of Technical Terms

- 1 Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- 2 Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- 3 Running Annual Average (RAA):** Regulatory compliance with some MCLs is based on running annual average of monthly samples.

- 4 Locational Running Annual Average (LRAA):** Regulatory compliance with some MCLs is based on locational running annual average or running annual average of monthly samples.
- 5 Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
- 6 Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.
- 7 Mg/l or ppm:** Milligrams per liter or parts per million – or one ounce in 7,350 gallons of water.
- 8 Ug/L or ppb:** Micrograms per liter or parts per billion—or one ounce in 7,350,000 gallons of water.

**SU:** Standard Unit  
**NA:** Not applicable.

- 9 Maximum Residual Disinfectant Level or (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- 10 Maximum Residual Disinfectant Level Goal or (MRDLG):** The level of a drinking water disinfectant below which there is not known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.
- 11 Nephelometric Turbidity Unit (NTU):** Nephelometric turbidity is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

## Powdersville Water—System SC0420002

Lead and Copper							
	Units	MCLG	Action Level	90 <sup>th</sup> Percentile	# Sites over AL	Date Sampled	Violation
Copper – Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing	ppm	1.3	1.3	0.057	0	2021	No
Lead – Corrosion of household plumbing system; Erosion of natural deposits	ppb	0	15	0.003	1	2021	No
Organics							
Distribution System	Units	MCLG	MCL	Range	Level Detected	Date Sampled	Violation
TTHMs (Total Trihalomethanes) – Byproducts of disinfection	ppb	N/A	80	8.4 – 40.8	RAA = 35.85	2022	No
HAA (Halocetic Acids) – Byproducts of disinfection	ppb	N/A	60	7.8 – 20.7	RAA = 14.4	2022	No

## Greenville Water—SC2310001

Should you need further information, please contact Jeff Phillips (Director of Water Resources) at 864-241-6155

Inorganics							
Parameter and Typical Source – Adkins Plant	Units	MCLG	MCL	Level Detected	Range	Date Sampled	Violation
Flouride – Erosion of natural deposits; additives for strong teeth	ppm	4	4	0.6	N/A	2022	No
Nitrate – Runoff from fertilizer use; Erosion of natural deposits; Byproducts of nitrification	ppm	10	10	0.06	N/A	2022	No
Organics							
Distribution System	Units	MCLG	MCL	Level Detected	Range	Date Sampled	Violation
TTHMs (Total Trihalomethanes) – Byproducts of disinfection	ppb	0	80	LRAA = 12.7	8.3-14.4	2022	No
HAA (Halocetic Acids) – Byproducts of disinfection	ppb	0	60	LRAA = 12.0	1.3-15.3	2022	No
Total Organic Carbon							
Typical Source – Adkins Plant	MCLG	MCL	% Removal	Range	Date Sampled	Violation	
Naturally present in the environment *Due to low raw water TOC levels are in compliance	N/A	TT	15% (35% required)	0.9-48%	Samples taken monthly	No	
Microbiological							
Turbidity – Adkins Plant	Units	MCLG	MCL	Level Detected	Average	Violation	
Turbidity	NTU	N/A	<0.3	Max = .06	0.04	No	
Total Coliform Common in environment; human and animal waste	% positive per month	N/A	Less than 5%	0% to .33% Monthly	N/A	No	
Disinfectant							
Parameter	Units	MRDLG	MRDL	Range	Running Annual Average	Violation	
Chloramine – Water additive to control microbes	ppm	4	4	ND–2.3	0.05-3.3	No	
Other Parameters							
Parameter	Units	MCL	Range	System Average			
PH	SU	6.5-8.5	7.0-8.4	7.6			

# Anderson Regional Joint Water System—SC0420011

Should you need further information, please contact Chris Weber (Operations Manager) at 864-332-6534

Organics							
Distribution System	Units	MCLG	MCL	Level Detected	Range	Date Sampled	Violation
TTHMs (Total Trihalomethanes) – Byproducts of disinfection	ppb	N/A	80	LRAA=18	7.6-18.3	2022	No
HAA (Halocetic Acids) – Byproducts of drinking water chlorination	ppb	N/A	60	LRAA=26	6.8-25.7	2022	No
Disinfectant							
Parameter	Units	MRDLG	MCL	Level Detected	Range	Date Sampled	Violation
Chlorine – Water additives used to control microbes	ppm	4	4	RAA=1.75	1.5-1.9	2021	No
Inorganics							
Parameter and Typical Source	Units	MCLG	MCL	Results	Range	Date Sampled	Violation
Flouride – Erosion of natural deposits; Additives for strong teeth	mg/l	4	4	0.58	0.58	2022	No
Nitrate – Runoff from fertilizer use; Erosion of natural deposits; Leaching from septic tanks, sewage	mg/l	10	10	0.14	0.14	2022	No
Turbidity	NTU	N/A	TT = 1 NTU	0.03-.30	99.5% of all samples taken are below MCL	2022	No
Microbiological							
	Units	MCLG	MCL	Results	Range	Date Sampled	Violation
Total Coliform – Common in environment; human and animal waste	0	0	0	0	0	2022	No
Fecal Coliform and E.coli – Common in environment; human and animal waste	0	0	0	0	0	2022	No
Total Organic Carbon (TOC)							
Typical Source	Units	Avg Source TOC	% Removal	Source TOC Range	Date Sampled	Violation	
Naturally present in the environment <i>*For source water's TOC level of &gt;2.0 mg/l, 35% removal is required— if not met technical treatment required</i>	mg/l	1.67 mg/l	35%	1.37-2.30	Samples taken monthly	No	
Other Parameters	Units	MCL	Annual Average	Date Sampled			
Alkalinity	mg/l	N/A	12.36	2022			
Hardness	mg/l	N/A	13.70	2022			
PH	SU	6.5-8.5	7.12	2022			

# Easley Combined Utilities—SC3910002 (Auxiliary Supply)

Should you need further information, please contact Roger Crowe (Water and Sewer Superintendent) or Tate Davis (Plant Operator) at 864-246-5817

Inorganics							
Parameter and Typical Source	Units	MCLG	MCL	Level Detected	Range	Date Sampled	Violation
Flouride – Erosion of natural deposits; Additives for strong teeth; Discharge from fertilizer factories	ppm	4	4	0.49	N/A	2022	No
Nitrate – Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits	ppm	10	10	0.13	N/A	2022	No
Organics							
Distribution System	Units	MCLG	MCL	Level Detected	Range	Date Sampled	Violation
TTHMs (Total Trihalomethanes) – Byproducts of drinking water chlorination	ppb	N/A	80	LRAA = 38	19.3-53.1	2022	No
HAA (Halocetic Acids) – Byproducts of drinking chlorination	ppb	N/A	60	LRAA = 32	21.0-39.7	2022	No
Microbiological							
	Units	MCLG	MCL	Level Detected	Range	Date Sampled	Violation
Turbidity @ Don L. Moore Water Treatment Plant Finished Water (Measured every four hours)	NTU	0	TT=0.3 NTU	Highest 0.04 NTU	N/A	2022	No
Turbidity – Lowest Monthly Percentage	NTU	0	TT=% of samples <0.3 NTU	100% of all samples taken 2022 below MCL	N/A	2022	No
Total Organic Carbon							
Typical Source	Units	MCLG	MCL	% Removal	Range	Date Sampled	Violation
Naturally present in the environment	mg/l	N/A	TT	78.9%	3.0-16.3	Samples taken monthly	No
Disinfectant							
Parameter	Units	MRDLG	MRDL	Range	Running Annual Average	Violation	
Free Chlorine	ppm	4	4	1.39-1.74	1.52	No	
Other Parameters							
Parameter	Units	MCL	System Average	SMCL	Range	Date Sampled	
PH	SU	N/A	7.3	6.5-8.5	6.8-7.9	2022	
Alkalinity	mg/l	N/A	12	N/A	N/A	2022	
Phosphate	mg/l	N/A	0.6	N/A	N/A	2022	
Hardness	mg/l	N/A	6	N/A	N/A	2022	

potential contamination by substances that are naturally-occurring or man-made. As source water travels over the land or underground it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be expected to contain at least small amounts of some contaminants. It's

possible to obtain more information about contaminants and potential health effects can be obtained by calling the EPA Safe Drinking Water Hotline at 1-800-426-4791. Contaminants that may be present in source water include:

- **Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems,
- **Pesticides and herbicides**, which may come from a variety of sources such as

## Things you should know.... (Continued)

agriculture, urban storm water runoff, and residential uses.

- **Organic chemical contaminants**, including synthetic and volatile organic chemicals which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water run-off, and septic systems.
- **Radioactive contaminants**, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health. Some people may be more vulnerable to small amounts of contaminants than the general population. Immune-compromised persons, such as cancer patients undergoing chemotherapy, organ transplant patients, persons with HIV/AIDS or other immune system disorders, some elderly people, and infants can be

particularly at risk from infections. Individuals with these conditions should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791). As previously stated, PW as well as our three suppliers, routinely sample for numerous contaminants in your drinking water according to federal and state regulations. As part of the EPA's requirements, each of our suppliers is required to submit their Annual Water Quality Report to PW. The information included in this report is dedicated to compiling and summarizing PW's system and also includes the water quality data from each of our source water providers for the period of January 1, 2022, to December 31, 2022. The information is somewhat technical, but it is important that you, the customer, understand that these records confirm that **PW's drinking water meets all applicable standards and is safe for your consumption. There were no recorded violations and none of the results exceeded the Maximum Contaminate Level (MCL) during the year 2022.**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing.

Powdersville Water is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components used on private property. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for thirty seconds to two minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.



### CONTACT YOUR HEALTH PROVIDER

If you are sensitive to contaminants or if you are at higher risk of infections



### CALL EPA'S SAFE WATER HOTLINE

at 1-800-426-4791 if you would like to know more about your CCR, or for more resources

## MESSAGE FROM THE MANAGER



Once again, your drinking water met all state and federal standards for the entire year of 2022. Our staff works hard each day to ensure that you receive quality drinking water every time you open the tap. We are charter members of AWWA's Distribution System Optimization (DSO) Program. This program requires us to meet operational benchmarks far beyond the required regulations. We have won AWWA's DSO Director's Award for the past 6 years (only system in SC to do so) and we are a better public water utility as a result!

We continue to invest annually in renourishing and replacing aging infrastructure in our distribution system, as well as building new capacity in the system for growth. After completing a Water Resources Master Plan in 2019, our Board of Directors has authorized the construction of several new transmission main projects that will enable us to serve the projected demands for the next 25 years. In the midst of all of this activity, Powdersville Water also provided you with safe drinking water for all of 2022 that exceeded all regulatory requirements. I attribute this success to a dedicated staff of employees that care about what they do for a living. Delivering safe drinking water to the public is a major responsibility and I want you to know that we take that charge very seriously at Powdersville Water.

This report is a testament to our staff's dedication. We are privileged to serve you and we want you to know that we are doing our job to make your drinking water safe. Thank you for allowing us to serve you.

Have a great summer!

*Dyke Spencer, Executive Director*



1719 Circle Road  
Powdersville, SC 29642  
864-269-5440

[www.PowdersvilleWater.org](http://www.PowdersvilleWater.org)

## Board of Directors

**Phil Landreth** – Chairman  
**Seth Landrum** – Vice Chairman  
**Kyle Dillard** – Treasurer  
**Terressa Batson** – Secretary

Robbie Binnicker, Matthew Eller,  
Towers Rice, JT Tingen,  
Suzanne Childs

## Staff

Dyke Spencer – Executive Director  
Robin Gore – Director of Finance & Administration  
Chris Rasco – Project Engineer  
Evan Landreth – Customer Service Manager  
Chris White – Operations Manager

Board meetings are scheduled on the third Thursday of each month at 5:30pm.  
**For more information, call 864-269-5440**